

# SPM Software Installation Instructions

Version 2.8.16

The Setra Power Meter is fully upgradable in the field to ensure the latest features and most robust experience is available. It is highly recommended that the meters be upgraded to the latest software revision available (2.8.16). It is required that when upgrading the meter to 2.8.16 that the procedure in the table below is followed to ensure proper upgrade:

	Upgrade steps					
Installed version	1	2	3	4	5	6
2.8.9	Download Configuration & Data File*	Factory Reset the Meter* (Data will be erased)	Upgrade to 2.8.10	Upgrade to 2.8.12	Upgrade to 2.8.10	Reload configuration**
2.8.10			Upgrade to 2.8.12	Upgrade to 2.8.15	Reload configuration**	
2.8.11			Upgrade to 2.8.12	Upgrade to 2.8.15		
2.8.12			Upgrade to 2.8.15	Reload configuration**		
2.8.13			Upgrade to 2.8.15			
2.8.14			Upgrade to 2.8.15			
2.8.15			Upgrade to 2.8.15			

## Setra Power Meter Downloads

To update software version\*\*\*:

1. Download new software version from link above.
2. Log into the web portal
3. Click System page from the sidebar
4. In the Software Version window, Click UPDATE button
5. Choose new file from saved location, unit will take a few minutes to load new software and reboot
6. If reboot does not happen automatically, close out the portal tab.
  - a. After another 10 minutes, power cycle the meter.

\*\*\* Total upgrade time with reboot is approximately 6mins

### Software Version

Firmware version  
2.8.13

UPDATE

Choose a file

CLOSE

Name

powermeter-os-swu-powermeter-protob-2.8.14.swu

14%

Uploading firmware. Please wait.

## Have a question?



Talk to a Setra representative today about your project needs.



800.257.3872



www.setra.com